

Recall Alert

U.S. Consumer Product Safety Commission

Office of Information and Public Affairs

Washington, DC 20207

March 11, 2003

CPSC, Fire-Lite Alarms Announce Recall of Power Supply for Alarm Systems

PRODUCT: Alarm System Power Supply - Fire-Lite Alarms, Inc. of Northford, Conn., is voluntarily recalling about 2600 power supplies used with building alarm systems. They are used with notification appliance circuits that provide an audible, visual, or audio-visual combination notification to building occupants in the event of a fire. The recalled power supplies were sold nationwide from September 2001 through November 2002 under the Fire-Lite and Notifier brand names for \$480 to \$530. Only power supplies with a date code of 4602 or lower are included in this recall.

PROBLEM: Fire-Lite models FCPS-24FS6 and FCPS-24FS8, and Notifier models FCPS-24S6 and FCPS-24S8 can have incomplete solder connections. The Notifier model ACPS-2406 can have an improper circuit response with low input voltage. Both of these conditions may result in a building alarm system not functioning properly.

INCIDENTS/INJURIES: No incidents have been reported.

WHAT TO DO: Building owners and maintenance personnel with Fire-Lite or Notifier power supplies should contact the Customer Service and Technical Support Center at (203) 484-7161 between 8 a.m. and 5 p.m. ET Monday through Friday.



[Send the link for this page to a friend!](#) The U.S. Consumer Product Safety Commission is charged with protecting the public from unreasonable risks of serious injury or death from more than 15,000 types of consumer products under the agency's jurisdiction. Deaths, injuries and property damage from consumer product incidents cost the nation more than \$700 billion annually. The CPSC is committed to protecting consumers and families from products that pose a fire, electrical, chemical, or mechanical hazard or can injure children. The CPSC's work to ensure the safety of consumer products - such as toys, cribs, power tools, cigarette lighters, and household chemicals - contributed significantly to the 30 percent decline in the rate of deaths and injuries associated with consumer products over the past 30 years.

To report a dangerous product or a product-related injury, call CPSC's hotline at (800) 638-2772 or CPSC's teletypewriter at (800) 638-8270, or visit CPSC's web site at www.cpsc.gov/talk.html. To join a CPSC email subscription list, please go to www.cpsc.gov/cpsclist.asp. Consumers can obtain this release and recall information at CPSC's Web site at www.cpsc.gov.